


Office of The Chief Medical Officer, Ghaziabad

Ref. No. DMO/IDSP/2018/905

Dated 21.09.2018

Safe Drinking Water, Health & Hygiene Certificate

It is certified that a combined inspection team headed by Mr. Narendra Kumar from CMO Office, Ghaziabad and Nagar Nigam Ghaziabad inspected the premises of **Uttam School For Girls School, B- Block, Shastri Nagar, Ghaziabad** on **17.09.2018** and found that Uttam School For Girls School has safe Drinking water facilities for the students and Staff/ members of the said Institution & is maintaining hygienic sanitation conditions in the school, in the building and the campus as per the norms.



(G.K. Mishra)
District Malaria Officer
Ghaziabad
G.K. Mishra
District Malaria officer
Ghaziabad

To

**Uttam School For Girls School
B - Block, Shastri Nagar, Ghaziabad**

OFFICE CHIEF MEDICAL OFFICER, GHAZIABAD

IDSP LAB


District- Ghaziabad

Date: 19/11/18


H₂S Strip test for contamination of water

S. NO	DATE	SAMPLE NO	ADDRESS	MOB NO	RESULT
1	12/10/18	341	Uttam School for Girls		Positive
2			Chaitri Nagar GPO		
3			0120-2753444		
4					
5					
6					
7					

Referred to CMO Ghaziabad for necessary action


Lab Assistant
IDSP, Ghaziabad

Microbiologist
IDSP, Ghaziabad


District Malaria Officer
Ghaziabad



Newcon Consultants & Laboratories

An ISO 9001 : 2015, ISO 14001 : 2015, OHSAS 18001 : 2007 Certified Laboratory
NABL ISO/IEC 17025 : 2005 (Testing, Cert. No. TC-5526) Accredited Laboratory,
Recognised with MOEFCC & U.P. Pollution Control Board



ISO 9001/14001/OHSAS 18001
Reg. No. R191/7381

Website : www.newconlab.in

TEST CERTIFICATE

WATER SAMPLE ANALYSIS REPORT (ESSENTIAL TEST AS PER IS:10500)

Page 1 Of 1

TEST REPORT NO : NCL/US/004/04/07/2018	DATE OF REPORT : 07/07/2018
Name And Address Of Customer	UTTAM SCHOOL FOR GIRL BLOCK - B, SHASTRI NAGAR, , GHAZIABAD, U.P., INDIA

SAMPLING DETAILS

Analysis Start Date	04/07/2018	Analysis End Date	07/07/2018
Date of Sampling	04/07/2018	Sampling ID No.	004/04/07/2018
Time of Sampling	11:20		
Sampling Done By	NCL		
Sampling Description	Drinking Water		
Sampling Location	CANTEEN WATER COOLER (R.O.)		
Sampling Protocol	IS:3025(Part-I)	Sampling Quantity	Two Lt
Packing Condition	Sealed	Packed In	PVC BOTTLE

TEST RESULT

S.No.	Parameter	Unit	Protocol	Result	Drinking Water Standards / Limit (IS :10500)	
					Desirable Limit	Permissible Limit
1	Colour	Hazen	APHA-2120 (C)	<5.0	5 max.	15 max.
2	Odour	--	IS:3025 (P-5)	Agreeable	Agreeable	Agreeable
3	Taste	--	IS:3025 (P-8)	Agreeable	Agreeable	Agreeable
4	Turbidity	NTU	APHA-2130 (B)	<1.0	1 max.	5 max.
5	pH	--	APHA-4500 (H+B)	6.98	6.5-8.5	No Relaxation
6	Total Hardness	mg/L	APHA-2340 (C)	18.5	200 max.	500 max.
7	Iron (Fe)	mg/L	APHA-3111 (B)	0.09	0.3 max.	No Relaxation
8	Chloride (Cl)	mg/L	APHA-4500 (B)	15.8	250 max.	1000 max.
9	Residual free Chlorine	mg/L	APHA-4500 (S)	<0.2	0.2 min.	1
10	Sulphates (SO4)	mg/L	APHA-4500 (C)	5.2	200 max.	400 max.
11	Total Alkalinity	mg/L	APHA-2320 (B)	22.9	200 max.	600 max.
12	Fluoride (F)	mg/L	APHA-4500 F- (F)	0.07	1.0 max.	1.5 max.
13	Total dissolved Solids (TDS)	mg/L	APHA-2540 (C)	68	500 max.	2000 max.
14	Total Coliform	/100ml	IS:1622-1981	Absent	Absent	Absent
15	E.coli	/100 mL	IS:1622-1981	Absent	Absent	Absent


Note:- Above tested parameter are well within the norm of Drinking water specification as per IS:10500-2012

**** End Of Report****

FOR NEWCON CONSULTANTS & LABORATORIES

INTEKHAB KHAN
M. Tech (Civil Science)
CHECKED BY

Format no NCL/QSP-28/TC-DWT/FMT-05 Rev.No.1 Date 18.07.2011



AUTHORIZED SIGNATORY

NOTE : 1. The Results reported above pertains to the Tested parameters only. Endorsement of the same is neither inferred nor implied. 2. All disputes subject to GHAZIABAD JURISDICTION. 3. The Report shall not be reproduced except in full without the permission of CHIEF ANALYST. 4. Our liability is limited to invoiced value only.

Laboratory : 8th K.M. Stone, NH-58, Delhi Meerut Road, Merta (Opp. Manan Dham Mandir) GHAZIABAD - 201 003 (U.P.) Telefax : (0120) 2875225, Mobile : 9810430345
E-mail : info@newconlab.in, newconlab@gmail.com